



SAYBOLT LP  
400 SWENSON DRIVE  
KENILWORTH, NJ 07033  
908-245-3100 Telephone  
908-245-5828 Facsimile

Fast To The Point

✓  
Book  
Saybolt LP

## Certificate of Analysis

Report Date: 2/6/2006  
Job No: 13031-00003004  
Client Ref: ST#15

Product: #6 F/O  
Location: Sprague, Rensselaer, NY

Test	Method	Result	Units
Lab Number: 2006020054-01		Sample ID: ST 15 (upper)	
Date Sampled 2/6/2006			
Gravity °API @ 60°F	ASTM D-4052	11.7	@ 60 °F
Sulfur	ASTM D-4294	1.20	Wt%
Lab Number: 2006020054-02		Sample ID: ST 15 (middle)	
Date Sampled 2/6/2006			
Gravity °API @ 60°F	ASTM D-4052	11.7	@ 60 °F
Sulfur	ASTM D-4294	1.20	Wt%
Lab Number: 2006020054-03		Sample ID: ST 15 (lower)	
Date Sampled 2/6/2006			
Gravity °API @ 60°F	ASTM D-4052	11.7	@ 60 °F
Sulfur	ASTM D-4294	1.20	Wt%
Lab Number: 2006020054-04		Sample ID: ST 15 (suction)	
Date Sampled 2/6/2006			
Gravity °API @ 60°F	ASTM D-4052	11.8	@ 60 °F
Sulfur	ASTM D-4294	1.19	Wt%

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.

Approved By:

Denise Apruzzi  
Laboratory Manager

Issuer warrants that it has exercised due diligence and care with respect to the information and professional judgments embodied in this report. This report reflects only the findings at the time and place of inspection and testing. Issuer expressly disclaims any further indemnity of any kind. This report is not a guarantee or policy of insurance with respect to the goods or the contractual performance of any party. Any person relying upon this report should be aware that issuer's activities are carried out under their general terms and conditions.

"Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D 3244 (except for analysis of RFG), IP 367 and appendix E of IP standard methods for analysis testing with respect to the utilization of test data to determine conformance with specifications"